

## STREET DEPARTMENT NOVEMBER 2021 MONTHLY REPORT

- 1. Worked on soda ash pump, changed diaphragm, and cleaned check values in pump at well 6.
- 2. Trimmed branches on Cedar st. and S. Cannon st.
- 3. Assisted in routine duties and repairs in wells.
- 4. Assisted in draining H/S water tower and replacing 12" value.
- 5. Replaced timer on N. Main st. Chrismas lights.
- 6. Removed fuel tanks from wastewater plant.
- 7. Replaced locks on Townhall back door.
- 8. Took dump truck to DMV for tags.
- 9. Cut out sink hole on Williams st. filled with CR6.
- 10. Dug up sewer line for disconnection at 103 S. Main st.
- 11. Completed all locate tickets
- 12. Performed routine and assisted dutines.

Rick Passwaters, Superintendent

Street Department